

MATERIALS		
ITEM	QUANT.	DESCRIPTION
1	1	ENCLOSURE, WATER PLUS CORPORATION MODEL #131632
2	1	AIR RELEASE VALVE 2" NPT, ARI MODEL D-040 FOR WATER OR RECLAIMED WATER.
3	1	1" CURB STOP, S.S.
4	1	2" x 4" NIPPLE, S.S.
5	1	2" BALL VALVE, PVC OR SST (WITH SST HANDLE AND SST NUTS)
6	1	2" TEE, S.S.
7	1	2" X 1" REDUCER, S.S.
8	1	1" SHORT NIPPLE, S.S.
9		NOT USED
10		NOT USED
11		NOT USED
12	1	2" DOUBLE STRAP TAPPING SADDLE, STAINLESS STEEL
13	1	4" & LARGER PIPE, D.I. OR PVC (DR-18)
14	1	AMERICAN MODEL 4001 2" SST FLANGED BALL VALVE WITH GEAR OPERATOR, 90° WITH 2" OPERATING NUT
15	2	1-1/2" PIPE, PVC, LENGTH AS REQUIRED
16	1	1-1/2" x 90° ELBOW, PVC

GENERAL NOTE(S):

- AIR RELEASE VALVES 2" IN DIAMETER SHALL BE USED ON 4" THROUGH 16" DIAMETER WATER OR RECLAIMED MAINS.

KEYED NOTE(S):

- ENCLOSURE SHALL BE COLOR CODED BLUE FOR POTABLE WATER AND PURPLE FOR RECLAIMED WATER.
- CONNECT TRACER WIRES FROM MAIN TO SERVICE WITH PRO-LINE TRACER-LOCK CONNECTORS. PART # TL-LUG-SS.
- PROVIDE ENOUGH TRACER WIRE SO IT CAN EXTEND AT LEAST 8-INCHES ABOVE GRADE.

