



GENERAL NOTE(S):

- A. DURING CONSTRUCTION, PROVIDE TEMPORARY PROTECTIVE FENCE AROUND CLEANOUT PER (324).
- B. SOLVENT WELD ALL PVC FITTINGS.
- C. DURING DESIGN AND CONSTRUCTION, REVIEW LATERAL LOCATION RELATIVE TO PROPOSED DRIVEWAY. STRONG CITY OF ALACHUA PREFERENCE IS FOR CLEAN-OUT NOT TO BE INSTALLED IN DRIVEWAY. SEE CITY OF ALACHUA DESIGN AND CONSTRUCTION MANUAL.

KEYED NOTE(S):

- ① CONTRACTOR SHALL VERIFY SUFFICIENT VERTICAL DIMENSION TO INSTALL UTILITIES ABOVE LATERAL.
- ② DO NOT CONNECT HOUSE PLUMBING TO STUB RISER.
- ③ DETAIL SHOWS CLEAN-OUT (CO) IN MIDDLE OF PUE, A STRONG CITY PREFERENCE. CITY MUST APPROVE ALL OTHER CLEANOUT LOCATIONS.
- ④ TEMPO OMNI MARKER II: ELECTRONIC MARKER, SANITARY GREEN, MODEL OM-6, PART 52085009.

200

**WASTEWATER SERVICE LATERAL
NTS**

