



1. DESIGNER/OWNER SHALL SUBMIT TANK VOLUME CALCULATIONS. REQUIRED TANK VOLUME SHALL BE CONFIRMED BY CITY OF ALACHUA, 1000 GALLON MINIMUM TANK VOLUME. STRUCTURAL DESIGN SHALL BE THE RESPONSIBILITY OF THE TANK MANUFACTURER.
2. ONLY KITCHEN WASTE SHALL BE DISCHARGED INTO THE GREASE INTERCEPTOR. ALL DOMESTIC WASTE (i.e. RESTROOMS) SHALL BE CONNECTED DOWNSTREAM OF THE GREASE INTERCEPTOR.
3. MANHOLES THAT ARE NOT INSTALLED UNDER PAVEMENT SHALL HAVE A RIM ELEVATION AT LEAST 6" ABOVE FINISHED GRADE AND A 10:1 SLOPE TO FINISHED GRADE.
4. GREASE INTERCEPTOR ASSEMBLY TO BE H-20 TRAFFIC LOAD RATED - INCLUDING TANK, TANK LID, CHIMNEYS, AND MANHOLE RING & COVER.
5. NO CAPPED TEES.

KEYED NOTE(S):

- ① IF REQUIRED, PROVIDE CONNECTION FOR BUILDING VENT. COORDINATE WITH BUILDING DESIGNER.

227

**GREASE INTERCEPTOR
NTS**

