



GENERAL NOTE(S)

- A. USE THIS DETAIL TO RESOLVE CONFLICT BETWEEN UPPER AND LOWER PIPES
- B. REFER TO (266H)
- C. MAINTAIN TRACER WIRE CONTINUITY, REFER TO (266H)
- D. IF THIS DETAIL IS NOT TECHNICALLY FEASIBLE AND IF APPROVED BY COA, SEPARATE PIPES AS PER RULE 62-555.314, F.A.C.

KEYED NOTE(S)

- ① FOR ALTERNATE TIE ROD RESTRAINT, REFER TO (266F). MAXIMUM ALLOWABLE TIE ROD LENGTH = 5'-0"
- ② CENTER HORIZONTAL PIPE SEGMENT ON CENTER OF EXISTING GRAVITY PIPE
- ③ INSTALLING WATER MAIN UNDER WW FORCE MAIN IS NOT COA PREFERENCE. CONTACT COA STAFF AND REFER TO DESIGN AND CONSTRUCTION MANUAL.

266D

RESOLVING UPPER AND LOWER PIPE CROSSING CONFLICTS

NTS

