

GENERAL NOTE(S)

- A. SUITABLE FOR 4" - 16" PIPE SIZES.**
- B. REMOVE DEFECTIVE PIPE SEGMENT. REPLACE WITH NEW PIPE SEGMENT WITH MINIMUM LENGTH OF 3' 0".**
- C. RESTRAIN ALL JOINTS, UNLESS OTHERWISE SHOWN.**
- D. INSTALL MJ FITTINGS AS PER AWWA C600, WHICH INCLUDES:**
- **CLEANING SOCKET AND PLAIN END.**
 - **LUBRICATING GASKET AND PLAIN END.**
 - **FURNISHING AND INSTALLING USING T-BOLT AND NUT FASTENERS.**
 - **FOR PIPE SIZES 4" - 16", BOLT SIZE SHALL BE ¾-INCH.**
 - **TIGHTENING TO SPECIFIED TORQUE RANGE.**
- E. DEPENDING ON PIPE MATERIALS AND WHETHER PIPE IS NEW OR EXISTING, ACCEPTABLE MJ RESTRAINT PRODUCTS INCLUDE:**
- **EBAA MEGALUG SERIES 1100.**
 - **EBAA MEGALUG SERIES 1100SD.**
 - **EBAA MEGALUG SERIES 2000PV.**
 - **EBAA MEGALUG SERIES 2000SVD.**
- F. ACCEPTABLE ALTERNATIVE TO MJ RESTRAINT IS TIE-ROD RESTRAINT. SEE DETAILS 266E AND 266F.**
- G. FOR MJ RESTRAINT AND MJ GLANDS (NON-RESTRAINED), PROVIDE GASKET.**
- H. FIELD INSPECT FOR PRESENCE OF TRACER WIRE. IF PRESENT, MAINTAIN TRACER WIRE CONTINUITY. PROVIDE NEW TRACER WIRE AS REQUIRED. CONNECT TRACER WIRE USING PRO-LINE TRACER-LOCK CONNECTORS, PART # TL-LUG-SS.**
- I. ABBREVIATIONS:**
- **MJ = MECHANICAL JOINT**
 - **DI = DUCTILE IRON**
 - **PVC = POLYVINYL CHLORIDE**

266H

**WATER/WASTEWATER PIPE REPAIR
GENERAL NOTES**

NTS

