

KEYED NOTE(S):

- ① WATER METER SERVICE SHALL BE 2" PVC, OATEY PRIMER AND SOLVENT WELD JOINTS. LOCATE TO AVOID CONFLICT WITH LOCATIONS OF ELECTRIC TRANSFORMERS AND FIRE HYDRANTS.
- ② ELECTRIC CONDUCTORS MAY BE ON EITHER SIDE OF THE ROADWAY. WATERMAIN SHOULD BE ON THE OPPOSITE SIDE OF TRANSFORMERS.
- ③ PVC SLEEVE TO BE 4" BLUE SCHEDULE 40 PVC SOLVENT WELD.
- ④ SEAL BOTH ENDS OF 4" SLEEVE WITH RAMNEK OR EQUAL.
- ⑤ MARK LOCATION OF SLEEVE CROSSING WITH "X" ON BACK OF CURB. **421**

