



- NOTE(S):**
1. SAWCUT CONTROL JOINTS SHALL BE CONSTRUCTED 5 FEET ON CENTER
 2. ALL CONCRETE SHALL BE CLASS I NON-STRUCTURAL.

1" BEDDING SAND (ASTM C33)

6" REINFORCED CONCRETE SLAB (3000 PSI MIN.)

12" STABILIZED TYPE B SUBGRADE MIN. LBR 40 COMPACTION 98% AASHTO T-180

405A

CROSS-WALK BRICK PAVER PAVEMENT DETAIL
NTS

