



**NOTES:**

1. POLE SHALL NOT BE LOCATED IN RIGHT-OF-WAY.
2. SERVICE DROP MINIMUM CLEARANCE (ABOVE FINISHED GRADE):
  - 16' - ABOVE RESIDENTIAL DRIVEWAYS
  - 18' - ABOVE PUBLIC DRIVEWAYS, ALLEYS AND ROADS

548

**TYPICAL OVERHEAD TEMPORARY SERVICE INSTALLATION**

**NTS**

