



**NOTES:**

1. TO ALLOW ROOM FOR CONSTRUCTION AND MAINTENANCE, PROVIDE A MINIMUM OF TEN (10) FEET OF CLEARANCE AND LEVEL, STABILIZED EARTH IN FRONT OF DOORS AND FOUR (4) FEET OF CLEARANCE AND LEVEL, STABILIZED EARTH ON ALL OTHER SIDES OF PAD MOUNTED EQUIPMENT. DO NOT PLACE TREES, SHRUBS OR OTHER OBSTRUCTIONS IN THIS AREA.
2. ABBREVIATION: C & G = CURB AND GUTTER

**557**

**TYPICAL PAD-MOUNTED EQUIPMENT  
CLEARANCE  
NTS**

