## **NOTES:**

- 1. COA APPROVED METER CENTER FURNISHED AND INSTALLED BY CONTRACTOR AND MAINTAINED BY OWNER.
- 2. METER CENTERS WITH RING TYPE DESIGN SHALL BE FURNISHED BY CONTRACTOR WITH SCREW TYPE RINGS APPROVED BY COA.
- 3. LINE-SIDE DISCONNECT WITH OVERCURRENT DEVICE IS REQUIRED.
- 4. LOAD-SIDE SERVICE DISCONNECTS AND OVERCURRENT DEVICES ARE REQUIRED.
- 5. ALL CONDUCTORS AND CONDUITS SHALL BE FURNISHED AND INSTALLED BY CONTRACTOR AND MAINTAINED BY OWNER.
- 6. ALL CONNECTIONS IN THE TRANSFORMER WILL BE MADE BY COA.





