



NOTES:

1. LOCATE TRANSFORMER FRONT 8' TO 15' FROM PAVING FOR LINE TRUCK ACCESS.
2. LOCATE TRANSFORMER A MINIMUM OF 4' FROM THE BUILDING DRIP LINE AND 10' FROM ANY WINDOW OR DOOR.
3. MAINTAIN 10' SEPARATION FROM FIRE HYDRANT, TRASH DUMPSTER OR TRASH COMPACTOR.
4. TERMINATE CONDUITS FLUSH WITH TOP OF PAD.
5. CONCRETE SHALL BE 3500 PSI POURED IN PLACE OR COA-APPROVED PRECAST
6. PROVIDE 10 FEET OF LEVEL, STABILIZED EARTH AT FRONT AND BACK OF UNIT, AND 4- FEET AT EACH SIDE.

584B

**CONCRETE MOUNTING PAD AND CONDUIT
PLACEMENT FOR THREE-PHASE
TRANSFORMERS, 75-500 KVA
NTS**

